

**DECLARATION OF CONFORMITY** AL-0000418958 rev.A  
 (according to ISO/IEC 17050)

**Allegion (UK) Ltd.**

Declares under its sole responsibility that the Briton 4200 Series Contract Trim, listed below have been tested in accordance with the EN 1906:2012 requirements and achieved the below classification.

(See test No 2407)

UK SKU	MEA SKU
4204.19.SS	4201V.8.SS
4201.19.SS	4201U.8.SS
4205.19.SS	4201C.8.SS
4203.19.SS	4201L.8.SS

Coding system according to EN 1906								
Digit	1	2	3	4	5	6	7	8
	Category of use	Durability	Door mass	Fire resistance	Safety	Corrosion resistance	Security	Type of operation
Class	<b>3</b>	<b>7</b>	-	<b>B</b>	<b>1</b>	<b>3</b>	<b>0</b>	<b>B</b>

Furthermore the below listed products may be fitted to insulated timber or mineral composite based doorsets, to provide up to 120 minutes integrity performance and uninsulated metallic doorsets, to provide up to 240 minutes integrity performance if tested in accordance with BS EN 1634-1:2000.

(See Fire Assessment 143440 Briton lever sets)

UK SKU	MEA SKU
4204.19.SS	4201V.8.SS
4201.19.SS	4201U.8.SS
4205.19.SS	4201C.8.SS
4203.19.SS	4201L.8.SS
4213.8.SS	4201I.SS
4214.8.SS	4201L.SS
4215.8.SS	4201B.SS
**4210.SS	**4201WC.SS
**4211.SS	**4201WCD.SS
4200.5.FP	-
-	4201TT.SS

\*\* Not suitable for uninsulated metallic doorsets.

This declaration of conformity is issued under the sole responsibility of Allegion (UK) Ltd.  
Signed for and on behalf of Allegion (UK) Ltd:

Chris Crampton  
Controller - Unitary EMEA, Finance and Accounting



Allegion (UK) Limited  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ

7<sup>th</sup> February 2017