
CERTIFICATE OF APPROVAL

No CF 5588

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

QMI BUILDING METAL PRODUCTS MANUFACTURING LLC

Dubai Industrial City, Dubai,UAE
Tel: 971 4 4279598

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

QMI Fire Rated Self-Closing
Sliding Steel Doorset

TECHNICAL SCHEDULE

TS12 Hinged or Pivoted Fire
Doorsets with Metallic Leaves
and Frames

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Paul Duggan
Certification Manager



Issued: 20th October 2017
Revised: 16th January 2018
Valid to: 19th October 2022
Page 1 of 3



CERTIFICATE No CF 5588

QMI BUILDING METAL PRODUCTS

MANUFACTURING LLC

QMI Fire Rated Self-Closing Sliding Steel Doorset

1. This approval relates to the use of the above doorsets in providing fire resistance of 240 minutes integrity as defined in BS 476: Part 22: 1987.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The doors are approved on the basis of:
 - i) Initial type testing under the test reference RF007.
 - ii) A design appraisal against TS12.
 - iii) Certification of quality management system to ISO 9001: 2008.
 - iv) Inspection and surveillance of factory production control.
 - v) Audit testing as defined in TS12.
4. The doorsets comprise sliding, single-leaf steel door leaves with steel frames. Fire exposure may be from either direction.
5. This approval is applicable to complete doorsets only.
6. This approval is applicable to single-leaf, latched and unlatched, steel sliding doorsets with leaf dimensions up to those given in Table 1.
7. Any latching hardware items shall be CERTIFIRE approved or otherwise as specified in the data sheet.
8. The doorsets shall be mechanically fixed to wall constructions having a fire resistance of at least the same period as the doorset.
9. This certificate does not include any approval relating to the mechanical requirements of the doorsets specified in TS12.
10. Doorsets shall be single-leaf. Double-leaf doorsets are not included within the scope of this assessment.

CERTIFICATE No CF 5588
QMI BUILDING METAL PRODUCTS
MANUFACTURING LLC

QMI Fire Rated Self-Closing Sliding Steel Doorset

Table 1. Maximum Permitted Door Leaf Dimensions

Doorset Configuration	Integrity (mins)	Maximum Height (mm)	Maximum Width (mm)	Subject to Maximum Area of (m ²)
Single-leaf sliding doorset	60, 90, 120 & 240	4900	4500	22.05

11. Labels to the CERTIFIRE design referencing QMI BUILDING METAL PRODUCTS MANUFACTURING L.L.C., CERTIFIRE and CERTIFIRE Ref. No. CF5588 shall be affixed to each door in the prescribed position.
12. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name and mark together with the CERTIFIRE Certificate number (CF5588) and application where appropriate.