

Notified body No. 1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of Constancy of Performance,

1121-CPR-AAA027

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

“VON DUPRIN 22 / 33 / 35 / 98 / 99 (See ANNEX A) 2227 / 3327 / 3527 / 9827 / 9857 / 9927 / 9957 (See ANNEX B) Series” Panic Exit Devices

Intended use: For use on single and double leaf escape panic doors, including fire resisting/smoke control doors & locked doors on escape routes.

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence : 179381 / 181858 / 183724 & 188932 Fire Test Evidence : Warres 131072 & C132276	
Clause 4.2.1 Ability to release (for doors on panic routes) Release function Panic exit device mounting Exposed edges and corners Double doorset Single doorset Bar installation Bar length Bar projection Bar end Operating bar face Test rod Door face gap Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass > 0,5mm Pass Pass Z < 150mm > 60% W < 100mm Pass > 18mm Pass NPD Pass Pass Pass – (2227 / 3327 / 3527 / 9827 / 9857 / 9927 & 9957 Annex B Only) Pass Pass – (2227 / 3327 / 3527 / 9827 / 9857 / 9927 & 9957 Annex B Only) Door mass ≤ 200 Kg, door height ≤ 2500mm, door width ≤ 1016mm Pass < 80 N with the door unloaded, and < 220 N with the door loaded with 1 000 N Grade 2	BS EN 1125:2008

Certificate of Constancy of Performance,

1121-CPR-AAA027

<p>Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on panic routes) Corrosion resistance Temperature range</p> <p>Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance –Horizontal bar Abuse resistance –Vertical rod</p> <p>Final examination</p>	<p>Grade 3 : 96 h Operating forces at -10 C° and +60 C° < 50% in excess of the operating forces at +20 C° Pass Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 1 000 N 500 N – (2227 / 3327 / 3527 / 9827 / 9857 / 9927 & 9957 Annex B Only) < 80 N with the door unloaded, and < 220 N with the door loaded with 1 000 N</p>	<p>BS EN 1125 : 2008</p>
<p>Clause 4.2.1 Self closing ability C (for fire/smoke doors on panic routes) Re-engagement force</p>	<p>< 50 N</p>	
<p>Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on panic routes) Durability Re-engagement force</p>	<p>Grade 7: 200 000 cycles < 50 N</p>	
<p>Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on panic routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies –</p> <p>Additional requirements</p>	<p>Grade B: Suitable for use on fire/smoke door assemblies.</p>	
<p>Clause 4.1.25 Control of Dangerous substances</p>	<p>If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.</p>	

**Certificate of Constancy of Performance,
1121-CPR-AAA027**

Von Duprin Product Code	Single Door	Double Door	Approved with Alternate Keepers and sockets				
			299	299F	1609	304L	6113
ANNEX A							
99 99-F Rim	✓	✓	✓	✓	✓	-----	✓
EL99 Rim	✓	✓	✓	✓	✓	-----	✓
98 98-F Rim	✓	✓	✓	✓	✓	-----	✓
33A 33A-F Rim	✓	✓	✓	✓	✓	-----	-----
EL33A Rim	✓	✓	✓	✓	✓	-----	-----
35A 35A-F Rim	✓	✓	✓	✓	✓	-----	-----
EL35A Rim	✓	✓	✓	✓	✓	-----	-----
22 22-F Rim	✓	✓	✓	✓	✓	-----	-----
ANNEX B							
9927 9927-F Vertical	✓	✓	✓	✓	-----	✓	-----
9957 9957-F Vertical	✓	✓	✓	✓	-----	✓	-----
9827 9827-F Vertical	✓	✓	✓	✓	-----	✓	-----
9857 9857-F Vertical	✓	✓	✓	✓	-----	✓	-----
3327A 3327A-F Vertical	✓	✓	✓	✓	-----	✓	-----
3527A 3527A-F Vertical	✓	✓	✓	✓	-----	✓	-----
2227 2227-F Vertical	✓	✓	✓	✓	-----	✓	-----
Accessories : 99, 99-F, EL99 Series, 98, 98-F, EL98 Series, 35A, 35A-F, EL35A Series, 33A, 33A-F, EL33A Series, 22 & 22-F Series							
99 Series	✓	✓	990DT, 990NL, 990TP, 991K, 992L (Std), options #01, #02, #03, #07, #12 & #17, KEYLEX 2100 & KEYLEX 700				
98 Series	✓	✓	990DT, 990NL, 990TP, 991K, 992L (Std), options #01, #02, #03, #07, #12 & #17, KEYLEX 2100 & KEYLEX 700				
35A Series	✓	✓	360L, 360T, 386NL, 386DT, 388, KEYLEX 2100 & KEYLEX 700				
33A Series	✓	✓	360L, 360T, 386NL, 386DT, 388, KEYLEX 2100 & KEYLEX 700				
22 Series	✓	✓	210DT, 210NL, 210K, 230L, 230DT, 230NL, 230TP, 230L, KEYLEX 2100 & KEYLEX 700				



Certificate of Constancy of Performance

1121-CPR-AAA027

Produced for

Allegion (UK) Ltd
Bescot Crescent, Walsall, West Midlands, WS1 4DL

and produced in the manufacturing plant

B/005

This is coded form and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

BS EN 1125: 2008

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **06/06/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan
 Certification Manager
Warrington Certification Ltd

