

Notified body No. 1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of constancy of performance

1121-CPR- NA5001

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

6210 & 6223 Electric Strikes

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test evidence:331144 Fire Test Evidence 334654	
Self closing ability		EN 14846: 2008
5.4 Door mass and closing force	Grade 8= 200Kg door mass with maximum 15N closing force	
Annex A Fire/Smoke test requirements	NPD	
Durability of self closing		
5.3.2 Durability of latch action	Grade C= 200,000 test cycles with no load on latchbolt	
Resistance to Fire E(integrity) I(insulation)(for fire doors)		
5.5 Suitability for use on fire/smoke doors	Grade F= classification time greater than 120min	

Certificate of constancy of performance

1121-CPR- NA5001

produced for

**Allegion (UK) Ltd
Bescot Crescent,
Walsall,
West Midlands,
WS1 4DL**

and produced in the manufacturing plant

B/005


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 14846:2008

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **08/12/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan
Certification Manager
Warrington Certification Ltd

